

Tacoma Facility

1427 E 26th Street

Tacoma, WA 98421

(253) 272-7788


Quincy Facility


1302 NE Intermodal Way


Quincy, WA 98848

(509) 497-0350

EXPANSION COUPLINGS









Advantages & Highlights of Expansion Couplings

- Manufactured from Schedule 40 or 80 pipe conforming to UL 651 and NEMA TC-2 Electrical Polyvinyl Chloride (PVC) Conduit
- Compression formed interference fit conforms to UL651 and NEMA TC-3 Polyvinyl Chloride (PVC) Fittings for Use with Rigid PVC Conduit and Tubing
- Couplings are intended to be joined with a cement that is or contains a solvent for polyvinyl chloride
- 6" travel minimum travel distance
- Made with 2 buna rubber O-rings separated by 7/16" - 1/2" and lubricated with Way Oil Vistac 68
- Dimensions are approximate and subject to normal manufacturing tolerances

All dimensions are inches